

TECHNICIAN'S CHECKLIST

SECTION 1631

EROSION CONTROL ROADSIDE DEVELOPMENT - ROLLED EROSION CONTROL PRODUCTS

PROJECT: _____

TECHNICIAN: _____

REVIEW DATE: _____

REVIEWER: _____

ACTION	YES	NO	N/A	COMMENTS
Review permits to determine if rolled products are prohibited.				
Ensure that the material to be used meets the requirements of Article 1054-5 or Article 1060-8.				
Use the proper type of lining for the ditch grade and water velocity.				
Use a sufficient width to accommodate the volume of water anticipated.				
Ensure that the stapling and/or staking is done immediately and that the material is trenched in at the proper intervals as detailed in the specifications at least every 50 feet along the ditch.				
Ensure that the matting is buried at the beginning edges of all rolls and at the leading edge of the ditches in a narrow trench at least 6" deep. Overlap ends 4". Construct staple checks 4" on center and 30' longitudinally.				
Staple ends, lapped edges and junctions 10" apart. Staple outer edges and down the center of each strip of matting 3' apart.				
Ensure netting is on the top side when excelsior or straw matting is used.				